

Table 1 – NSW Office of Water recommended modified Restriction Table (Oberon Dam)

Annual Dam at ML		Level 1 50%	Level 2 40%	Level 3 25%	Level 4 20%	Level 5 15%	Level 6 10%	Level 7 8%	Level 8 5%	
	<b>44,762</b>	<b>22,381</b>	<b>17,905</b>	<b>11,191</b>	<b>8,952</b>	<b>6,714</b>	<b>4,476</b>	<b>3,581</b>	<b>2,238</b>	
Restriction	Delta	20.0%	20.0%	30.0%	40.0%	60.0%	68.0%	98.0%	99.5%	
	SCA/LCC	10.0%	20.0%	30.0%	40.0%	60.0%	65.0%	65.0%	100.0% <sup>1</sup>	
	Oberon	0.0%	0.0%	0.0%	0.0%	10.0%	10.0%	10.0%	20.0%	
	Minor Consumers	10.0%	20.0%	20.0%	20.0%	20.0%	20.0%	50.0%	50.0%	
<b>Yearly</b>	<b>Shares</b>									
	Delta	8,184	6,547	6,547	5,729	4,910	3,274	2,619	164	41
	SCA	3,650	3,285	2,920	2,555	2,190	1,460	1,278	1,278	0
	Lithgow	1,778	1,600	1,422	1,245	1,067	711	622	622	0
	Oberon	1,064	1,064	1,064	1,064	1,064	958	958	958	851
	Min Cons	200	180	160	160	160	160	160	100	100
	<b>Totals</b>	<b>14,876</b>	<b>12,676</b>	<b>12,114</b>	<b>10,752</b>	<b>9,391</b>	<b>6,562</b>	<b>5,636</b>	<b>3,121</b>	<b>992</b>
<b>Monthly</b>	<b>Shares</b>									
	Delta	682	546	546	477	409	273	218	14	3
	SCA	304	274	243	213	183	122	106	106	0
	Lithgow	148	133	119	104	89	59	52	52	0
	Oberon	89	89	89	89	89	80	80	80	71
	Min Cons	17	15	13	13	13	13	13	8	8
	<b>Totals</b>	<b>1,240</b>	<b>1,056</b>	<b>1,009</b>	<b>896</b>	<b>783</b>	<b>547</b>	<b>470</b>	<b>260</b>	<b>83</b>
<b>Weekly</b>	<b>Shares</b>									
	Delta	157	126	126	110	94	63	50	3	1
	SCA	70	63	56	49	42	28	25	25	0
	Lithgow	34	31	27	24	21	14	12	12	0
	Oberon	20	20	20	20	20	18	18	18	16
	Min Cons	4	3	3	3	3	3	3	2	2
	<b>Totals</b>	<b>286</b>	<b>244</b>	<b>233</b>	<b>207</b>	<b>181</b>	<b>126</b>	<b>108</b>	<b>60</b>	<b>19</b>
<b>Daily</b>	<b>Shares</b>									
	Delta	22.4	17.9	17.9	15.7	13.4	9.0	7.2	0.4	0.1
	SCA	10.0	9.0	8.0	7.0	6.0	4.0	3.5	3.5	0.0
	Lithgow	4.9	4.4	3.9	3.4	2.9	1.9	1.7	1.7	0.0
	Oberon	2.9	2.9	2.9	2.9	2.9	2.6	2.6	2.6	2.3
	Min Cons	0.5	0.5	0.4	0.4	0.4	0.4	0.4	0.3	0.3
	<b>Totals</b>	<b>41</b>	<b>34.7</b>	<b>33.2</b>	<b>29.4</b>	<b>25.7</b>	<b>18.0</b>	<b>15.4</b>	<b>8.5</b>	<b>2.7</b>

Please note that all restrictions described above relate to net storage, that is the volume of water in storage, excluding any water in carry over accounts.

<sup>1</sup> In the event that SCA's Cascade storages are at critical levels (less than 50% storage), and maximum restrictions have been applied to the upper Blue Mountains villages, consideration will be given to allowing SCA to extract up to 3.5 ML/day from Oberon Dam. Simultaneously, a feasibility and comparative assessment will be initiated for emergency augmentation options for both Oberon Shire and the Upper Blue Mountains.