

NSW SWIMMING POOL REGISTER

Pool 'self assessment' checklist

Indoor Pools

	Does your pool meet the safety standards?	
Window restrictions for indoor pools		
The windows can only open to a maximum of 100mm	Yes	No
OR The windows are totally covered by bars or a mesh screen	Yes	No
OR The height from the sill of the lowest opening panel of a window (to the pool area) is at least 1800mm from the ground	Yes	No
Doors that have access to pools		
There is a latch on the door at least 1500mm above floor level	Yes	No
Doors open away from the pool area and are self-latching	Yes	No
There are no pet doors or openings greater than 100mm	Yes	No
Wall restrictions for indoor pools		
There are no wall openings greater than 100mm	Yes	No
Around the pool		
There is an appropriate warning sign, including details of resuscitation (CPR) techniques, in the immediate vicinity of the pool area which can be easily read from a distance of 3 metres.	Yes	No

If you have answered 'No' to any of the questions above, please contact your local council for further information.