

NSW Drinking Water Database
Microbiology
Drinking Water Monitoring Program

Barcode	Characteristic	Guideline Value	Units	Value	Sample Site Code	Sample Site Location	Lab Name	Date Collected	Date Received	Date Entered
125OB0100007	E. coli	0.	mpn/100 mL	< 1	5	Tarana Road Oberon	ICPMR-DAL Laboratory	07-04-2025	09-04-2025	10-04-2025
125OB0100007	Free Chlorine	0.2 - 5	mg/L	1.35	5	Tarana Road Oberon	ICPMR-DAL Laboratory	07-04-2025	09-04-2025	10-04-2025
125OB0100007	pH	6.5 - 8.5		7.9	5	Tarana Road Oberon	ICPMR-DAL Laboratory	07-04-2025	09-04-2025	10-04-2025
125OB0100007	Temperature	30.	C	17.8	5	Tarana Road Oberon	ICPMR-DAL Laboratory	07-04-2025	09-04-2025	10-04-2025
125OB0100007	Total Chlorine	5.	mg/L	1.742	5	Tarana Road Oberon	ICPMR-DAL Laboratory	07-04-2025	09-04-2025	10-04-2025
125OB0100007	Total Coliforms	0.	mpn/100 mL	< 1	5	Tarana Road Oberon	ICPMR-DAL Laboratory	07-04-2025	09-04-2025	10-04-2025
125OB0100007	Turbidity	5.	NTU	0.01	5	Tarana Road Oberon	ICPMR-DAL Laboratory	07-04-2025	09-04-2025	10-04-2025
125OB0100008	E. coli	0.	mpn/100 mL	< 1	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	14-04-2025	16-04-2025	17-04-2025
125OB0100008	Free Chlorine	0.2 - 5	mg/L	1.745	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	14-04-2025	16-04-2025	17-04-2025
125OB0100008	pH	6.5 - 8.5		7.71	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	14-04-2025	16-04-2025	17-04-2025
125OB0100008	Temperature	30.	C	18.	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	14-04-2025	16-04-2025	17-04-2025
125OB0100008	Total Chlorine	5.	mg/L	2.171	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	14-04-2025	16-04-2025	17-04-2025
125OB0100008	Total Coliforms	0.	mpn/100 mL	< 1	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	14-04-2025	16-04-2025	17-04-2025
125OB0100008	Turbidity	5.	NTU	0.06	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	14-04-2025	16-04-2025	17-04-2025
125OB0100009	E. coli	0.	mpn/100 mL	< 1	2	Albion Street Oberon	ICPMR-DAL Laboratory	22-04-2025	24-04-2025	28-04-2025
125OB0100009	Free Chlorine	0.2 - 5	mg/L	0.649	2	Albion Street Oberon	ICPMR-DAL Laboratory	22-04-2025	24-04-2025	28-04-2025
125OB0100009	pH	6.5 - 8.5		7.73	2	Albion Street Oberon	ICPMR-DAL Laboratory	22-04-2025	24-04-2025	28-04-2025
125OB0100009	Temperature	30.	C	17.8	2	Albion Street Oberon	ICPMR-DAL Laboratory	22-04-2025	24-04-2025	28-04-2025
125OB0100009	Total Chlorine	5.	mg/L	1.062	2	Albion Street Oberon	ICPMR-DAL Laboratory	22-04-2025	24-04-2025	28-04-2025
125OB0100009	Total Coliforms	0.	mpn/100 mL	< 1	2	Albion Street Oberon	ICPMR-DAL Laboratory	22-04-2025	24-04-2025	28-04-2025
125OB0100009	Turbidity	5.	NTU	0.02	2	Albion Street Oberon	ICPMR-DAL Laboratory	22-04-2025	24-04-2025	28-04-2025
125OB0100045	E. coli	0.	mpn/100 mL	< 1	3	Fairfax Street Oberon	ICPMR-DAL Laboratory	28-04-2025	29-04-2025	30-04-2025
125OB0100045	Free Chlorine	0.2 - 5	mg/L	1.058	3	Fairfax Street Oberon	ICPMR-DAL Laboratory	28-04-2025	29-04-2025	30-04-2025
125OB0100045	pH	6.5 - 8.5		7.74	3	Fairfax Street Oberon	ICPMR-DAL Laboratory	28-04-2025	29-04-2025	30-04-2025
125OB0100045	Temperature	30.	C	17.3	3	Fairfax Street Oberon	ICPMR-DAL Laboratory	28-04-2025	29-04-2025	30-04-2025
125OB0100045	Total Chlorine	5.	mg/L	1.54	3	Fairfax Street Oberon	ICPMR-DAL Laboratory	28-04-2025	29-04-2025	30-04-2025
125OB0100045	Total Coliforms	0.	mpn/100 mL	< 1	3	Fairfax Street Oberon	ICPMR-DAL Laboratory	28-04-2025	29-04-2025	30-04-2025
125OB0100045	Turbidity	5.	NTU	0.06	3	Fairfax Street Oberon	ICPMR-DAL Laboratory	28-04-2025	29-04-2025	30-04-2025
125OB0100044	E. coli	0.	mpn/100 mL	< 1	4	Carrington Avenue Oberon	ICPMR-DAL Laboratory	05-05-2025	06-05-2025	07-05-2025
125OB0100044	Free Chlorine	0.2 - 5	mg/L	0.946	4	Carrington Avenue Oberon	ICPMR-DAL Laboratory	05-05-2025	06-05-2025	07-05-2025
125OB0100044	pH	6.5 - 8.5		7.85	4	Carrington Avenue Oberon	ICPMR-DAL Laboratory	05-05-2025	06-05-2025	07-05-2025
125OB0100044	Temperature	30.	C	16.	4	Carrington Avenue Oberon	ICPMR-DAL Laboratory	05-05-2025	06-05-2025	07-05-2025
125OB0100044	Total Chlorine	5.	mg/L	1.355	4	Carrington Avenue Oberon	ICPMR-DAL Laboratory	05-05-2025	06-05-2025	07-05-2025
125OB0100044	Total Coliforms	0.	mpn/100 mL	< 1	4	Carrington Avenue Oberon	ICPMR-DAL Laboratory	05-05-2025	06-05-2025	07-05-2025
125OB0100044	Turbidity	5.	NTU	0.11	4	Carrington Avenue Oberon	ICPMR-DAL Laboratory	05-05-2025	06-05-2025	07-05-2025

125OB0100010	E. coli	0.	mpn/100 mL	< 1	5	Tarana Road Oberon	ICPMR-DAL Laboratory	12-05-2025	13-05-2025	14-05-2025
125OB0100010	Free Chlorine	0.2 - 5	mg/L	1.231	5	Tarana Road Oberon	ICPMR-DAL Laboratory	12-05-2025	13-05-2025	14-05-2025
125OB0100010	pH	6.5 - 8.5		7.65	5	Tarana Road Oberon	ICPMR-DAL Laboratory	12-05-2025	13-05-2025	14-05-2025
125OB0100010	Temperature	30.	C	16.8	5	Tarana Road Oberon	ICPMR-DAL Laboratory	12-05-2025	13-05-2025	14-05-2025
125OB0100010	Total Chlorine	5.	mg/L	1.649	5	Tarana Road Oberon	ICPMR-DAL Laboratory	12-05-2025	13-05-2025	14-05-2025
125OB0100010	Total Coliforms	0.	mpn/100 mL	< 1	5	Tarana Road Oberon	ICPMR-DAL Laboratory	12-05-2025	13-05-2025	14-05-2025
125OB0100010	Turbidity	5.	NTU	0.52	5	Tarana Road Oberon	ICPMR-DAL Laboratory	12-05-2025	13-05-2025	14-05-2025
125OB0100011	E. coli	0.	mpn/100 mL	< 1	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	19-05-2025	20-05-2025	21-05-2025
125OB0100011	Free Chlorine	0.2 - 5	mg/L	1.515	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	19-05-2025	20-05-2025	21-05-2025
125OB0100011	pH	6.5 - 8.5		7.73	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	19-05-2025	20-05-2025	21-05-2025
125OB0100011	Temperature	30.	C	14.7	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	19-05-2025	20-05-2025	21-05-2025
125OB0100011	Total Chlorine	5.	mg/L	1.944	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	19-05-2025	20-05-2025	21-05-2025
125OB0100011	Total Coliforms	0.	mpn/100 mL	< 1	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	19-05-2025	20-05-2025	21-05-2025
125OB0100011	Turbidity	5.	NTU	0.31	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	19-05-2025	20-05-2025	21-05-2025
125OB0100012	E. coli	0.	mpn/100 mL	< 1	2	Albion Street Oberon	ICPMR-DAL Laboratory	26-05-2025	27-05-2025	28-05-2025
125OB0100012	Free Chlorine	0.2 - 5	mg/L	0.84	2	Albion Street Oberon	ICPMR-DAL Laboratory	26-05-2025	27-05-2025	28-05-2025
125OB0100012	pH	6.5 - 8.5		7.61	2	Albion Street Oberon	ICPMR-DAL Laboratory	26-05-2025	27-05-2025	28-05-2025
125OB0100012	Temperature	30.	C	12.6	2	Albion Street Oberon	ICPMR-DAL Laboratory	26-05-2025	27-05-2025	28-05-2025
125OB0100012	Total Chlorine	5.	mg/L	1.242	2	Albion Street Oberon	ICPMR-DAL Laboratory	26-05-2025	27-05-2025	28-05-2025
125OB0100012	Total Coliforms	0.	mpn/100 mL	< 1	2	Albion Street Oberon	ICPMR-DAL Laboratory	26-05-2025	27-05-2025	28-05-2025
125OB0100012	Turbidity	5.	NTU	0.27	2	Albion Street Oberon	ICPMR-DAL Laboratory	26-05-2025	27-05-2025	28-05-2025
125OB0100013	E. coli	0.	mpn/100 mL	< 1	3	Fairfax Street Oberon	ICPMR-DAL Laboratory	02-06-2025	03-06-2025	04-06-2025
125OB0100013	Free Chlorine	0.2 - 5	mg/L	0.936	3	Fairfax Street Oberon	ICPMR-DAL Laboratory	02-06-2025	03-06-2025	04-06-2025
125OB0100013	pH	6.5 - 8.5		7.58	3	Fairfax Street Oberon	ICPMR-DAL Laboratory	02-06-2025	03-06-2025	04-06-2025
125OB0100013	Temperature	30.	C	13.7	3	Fairfax Street Oberon	ICPMR-DAL Laboratory	02-06-2025	03-06-2025	04-06-2025
125OB0100013	Total Chlorine	5.	mg/L	1.331	3	Fairfax Street Oberon	ICPMR-DAL Laboratory	02-06-2025	03-06-2025	04-06-2025
125OB0100013	Total Coliforms	0.	mpn/100 mL	< 1	3	Fairfax Street Oberon	ICPMR-DAL Laboratory	02-06-2025	03-06-2025	04-06-2025
125OB0100013	Turbidity	5.	NTU	0.22	3	Fairfax Street Oberon	ICPMR-DAL Laboratory	02-06-2025	03-06-2025	04-06-2025
125OB0100043	E. coli	0.	mpn/100 mL	< 1	4	Carrington Avenue Oberon	ICPMR-DAL Laboratory	10-06-2025	12-06-2025	13-06-2025
125OB0100043	Free Chlorine	0.2 - 5	mg/L	1.256	4	Carrington Avenue Oberon	ICPMR-DAL Laboratory	10-06-2025	12-06-2025	13-06-2025
125OB0100043	pH	6.5 - 8.5		7.89	4	Carrington Avenue Oberon	ICPMR-DAL Laboratory	10-06-2025	12-06-2025	13-06-2025
125OB0100043	Temperature	30.	C	10.7	4	Carrington Avenue Oberon	ICPMR-DAL Laboratory	10-06-2025	12-06-2025	13-06-2025
125OB0100043	Total Chlorine	5.	mg/L	1.66	4	Carrington Avenue Oberon	ICPMR-DAL Laboratory	10-06-2025	12-06-2025	13-06-2025
125OB0100043	Total Coliforms	0.	mpn/100 mL	< 1	4	Carrington Avenue Oberon	ICPMR-DAL Laboratory	10-06-2025	12-06-2025	13-06-2025
125OB0100043	Turbidity	5.	NTU	0.2	4	Carrington Avenue Oberon	ICPMR-DAL Laboratory	10-06-2025	12-06-2025	13-06-2025
125OB0100042	E. coli	0.	mpn/100 mL	< 1	5	Tarana Road Oberon	ICPMR-DAL Laboratory	16-06-2025	18-06-2025	19-06-2025
125OB0100042	Free Chlorine	0.2 - 5	mg/L	1.435	5	Tarana Road Oberon	ICPMR-DAL Laboratory	16-06-2025	18-06-2025	19-06-2025
125OB0100042	pH	6.5 - 8.5		7.87	5	Tarana Road Oberon	ICPMR-DAL Laboratory	16-06-2025	18-06-2025	19-06-2025

125OB0100042	Temperature	30.	C	10.6	5	Tarana Road Oberon	ICPMR-DAL Laboratory	16-06-2025	18-06-2025	19-06-2025
125OB0100042	Total Chlorine	5.	mg/L	1.919	5	Tarana Road Oberon	ICPMR-DAL Laboratory	16-06-2025	18-06-2025	19-06-2025
125OB0100042	Total Coliforms	0.	mpn/100 mL	< 1	5	Tarana Road Oberon	ICPMR-DAL Laboratory	16-06-2025	18-06-2025	19-06-2025
125OB0100042	Turbidity	5.	NTU	0.19	5	Tarana Road Oberon	ICPMR-DAL Laboratory	16-06-2025	18-06-2025	19-06-2025
125OB0100041	E. coli	0.	mpn/100 mL	< 1	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	23-06-2025	24-06-2025	25-06-2025
125OB0100041	Free Chlorine	0.2 - 5	mg/L	0.987	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	23-06-2025	24-06-2025	25-06-2025
125OB0100041	pH	6.5 - 8.5		7.87	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	23-06-2025	24-06-2025	25-06-2025
125OB0100041	Temperature	30.	C	10.8	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	23-06-2025	24-06-2025	25-06-2025
125OB0100041	Total Chlorine	5.	mg/L	1.482	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	23-06-2025	24-06-2025	25-06-2025
125OB0100041	Total Coliforms	0.	mpn/100 mL	< 1	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	23-06-2025	24-06-2025	25-06-2025
125OB0100041	Turbidity	5.	NTU	0.1	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	23-06-2025	24-06-2025	25-06-2025
125OB0100040	E. coli	0.	mpn/100 mL	< 1	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	01-07-2025	03-07-2025	04-07-2025
125OB0100040	Free Chlorine	0.2 - 5	mg/L	1.09	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	01-07-2025	03-07-2025	04-07-2025
125OB0100040	pH	6.5 - 8.5		7.89	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	01-07-2025	03-07-2025	04-07-2025
125OB0100040	Temperature	30.	C	8.9	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	01-07-2025	03-07-2025	04-07-2025
125OB0100040	Total Chlorine	5.	mg/L	1.584	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	01-07-2025	03-07-2025	04-07-2025
125OB0100040	Total Coliforms	0.	mpn/100 mL	< 1	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	01-07-2025	03-07-2025	04-07-2025
125OB0100040	Turbidity	5.	NTU	0.17	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	01-07-2025	03-07-2025	04-07-2025
125OB0100014	E. coli	0.	mpn/100 mL	< 1	3	Fairfax Street Oberon	ICPMR-DAL Laboratory	07-07-2025	08-07-2025	09-07-2025
125OB0100014	Free Chlorine	0.2 - 5	mg/L	0.969	3	Fairfax Street Oberon	ICPMR-DAL Laboratory	07-07-2025	08-07-2025	09-07-2025
125OB0100014	pH	6.5 - 8.5		7.67	3	Fairfax Street Oberon	ICPMR-DAL Laboratory	07-07-2025	08-07-2025	09-07-2025
125OB0100014	Temperature	30.	C	10.7	3	Fairfax Street Oberon	ICPMR-DAL Laboratory	07-07-2025	08-07-2025	09-07-2025
125OB0100014	Total Chlorine	5.	mg/L	1.447	3	Fairfax Street Oberon	ICPMR-DAL Laboratory	07-07-2025	08-07-2025	09-07-2025
125OB0100014	Total Coliforms	0.	mpn/100 mL	< 1	3	Fairfax Street Oberon	ICPMR-DAL Laboratory	07-07-2025	08-07-2025	09-07-2025
125OB0100014	Turbidity	5.	NTU	0.02	3	Fairfax Street Oberon	ICPMR-DAL Laboratory	07-07-2025	08-07-2025	09-07-2025
125OB0100015	E. coli	0.	mpn/100 mL	< 1	4	Carrington Avenue Oberon	ICPMR-DAL Laboratory	14-07-2025	16-07-2025	17-07-2025
125OB0100015	Free Chlorine	0.2 - 5	mg/L	0.912	4	Carrington Avenue Oberon	ICPMR-DAL Laboratory	14-07-2025	16-07-2025	17-07-2025
125OB0100015	pH	6.5 - 8.5		7.88	4	Carrington Avenue Oberon	ICPMR-DAL Laboratory	14-07-2025	16-07-2025	17-07-2025
125OB0100015	Temperature	30.	C	10.1	4	Carrington Avenue Oberon	ICPMR-DAL Laboratory	14-07-2025	16-07-2025	17-07-2025
125OB0100015	Total Chlorine	5.	mg/L	1.413	4	Carrington Avenue Oberon	ICPMR-DAL Laboratory	14-07-2025	16-07-2025	17-07-2025
125OB0100015	Total Coliforms	0.	mpn/100 mL	< 1	4	Carrington Avenue Oberon	ICPMR-DAL Laboratory	14-07-2025	16-07-2025	17-07-2025
125OB0100015	Turbidity	5.	NTU	0.	4	Carrington Avenue Oberon	ICPMR-DAL Laboratory	14-07-2025	16-07-2025	17-07-2025
125OB0100016	E. coli	0.	mpn/100 mL	< 1	5	Tarana Road Oberon	ICPMR-DAL Laboratory	21-07-2025	22-07-2025	23-07-2025
125OB0100016	Free Chlorine	0.2 - 5	mg/L	1.001	5	Tarana Road Oberon	ICPMR-DAL Laboratory	21-07-2025	22-07-2025	23-07-2025
125OB0100016	pH	6.5 - 8.5		7.78	5	Tarana Road Oberon	ICPMR-DAL Laboratory	21-07-2025	22-07-2025	23-07-2025
125OB0100016	Temperature	30.	C	9.3	5	Tarana Road Oberon	ICPMR-DAL Laboratory	21-07-2025	22-07-2025	23-07-2025
125OB0100016	Total Chlorine	5.	mg/L	1.48	5	Tarana Road Oberon	ICPMR-DAL Laboratory	21-07-2025	22-07-2025	23-07-2025
125OB0100016	Total Coliforms	0.	mpn/100 mL	< 1	5	Tarana Road Oberon	ICPMR-DAL Laboratory	21-07-2025	22-07-2025	23-07-2025

125OB0100016	Turbidity	5.	NTU	0.	5	Tarana Road Oberon	ICPMR-DAL Laboratory	21-07-2025	22-07-2025	23-07-2025
125OB0100017	E. coli	0.	mpn/100 mL	< 1	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	28-07-2025	29-07-2025	30-07-2025
125OB0100017	Free Chlorine	0.2 - 5	mg/L	1.164	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	28-07-2025	29-07-2025	30-07-2025
125OB0100017	pH	6.5 - 8.5		7.82	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	28-07-2025	29-07-2025	30-07-2025
125OB0100017	Temperature	30.	C	9.	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	28-07-2025	29-07-2025	30-07-2025
125OB0100017	Total Chlorine	5.	mg/L	1.623	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	28-07-2025	29-07-2025	30-07-2025
125OB0100017	Total Coliforms	0.	mpn/100 mL	< 1	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	28-07-2025	29-07-2025	30-07-2025
125OB0100017	Turbidity	5.	NTU	0.06	1	137 Oberon Street Oberon	ICPMR-DAL Laboratory	28-07-2025	29-07-2025	30-07-2025
125OB0100039	E. coli	0.	mpn/100 mL	< 1	2	Albion Street Oberon	ICPMR-DAL Laboratory	04-08-2025	06-08-2025	07-08-2025
125OB0100039	Free Chlorine	0.2 - 5	mg/L	1.078	2	Albion Street Oberon	ICPMR-DAL Laboratory	04-08-2025	06-08-2025	07-08-2025
125OB0100039	pH	6.5 - 8.5		7.79	2	Albion Street Oberon	ICPMR-DAL Laboratory	04-08-2025	06-08-2025	07-08-2025
125OB0100039	Temperature	30.	C	10.7	2	Albion Street Oberon	ICPMR-DAL Laboratory	04-08-2025	06-08-2025	07-08-2025
125OB0100039	Total Chlorine	5.	mg/L	1.46	2	Albion Street Oberon	ICPMR-DAL Laboratory	04-08-2025	06-08-2025	07-08-2025
125OB0100039	Total Coliforms	0.	mpn/100 mL	< 1	2	Albion Street Oberon	ICPMR-DAL Laboratory	04-08-2025	06-08-2025	07-08-2025
125OB0100039	Turbidity	5.	NTU	0.11	2	Albion Street Oberon	ICPMR-DAL Laboratory	04-08-2025	06-08-2025	07-08-2025
A25OB0100001	PFBS	1.	µg/L	< 0.001	R01	Raw/Source water	Enviro lab	12-05-2025	13-05-2025	16-05-2025
A25OB0100001	PFHxS	0.03	µg/L	< 0.001	R01	Raw/Source water	Enviro lab	12-05-2025	13-05-2025	16-05-2025
A25OB0100001	PFOA	0.2	µg/L	< 0.001	R01	Raw/Source water	Enviro lab	12-05-2025	13-05-2025	16-05-2025
A25OB0100001	PFOS	0.008	µg/L	< 0.001	R01	Raw/Source water	Enviro lab	12-05-2025	13-05-2025	16-05-2025
A25OB0100002	PFBS	1.	µg/L	< 0.001	N35	Oberon treatment plant outlet	Enviro lab	12-05-2025	13-05-2025	16-05-2025
A25OB0100002	PFHxS	0.03	µg/L	< 0.001	N35	Oberon treatment plant outlet	Enviro lab	12-05-2025	13-05-2025	16-05-2025
A25OB0100002	PFOA	0.2	µg/L	< 0.001	N35	Oberon treatment plant outlet	Enviro lab	12-05-2025	13-05-2025	16-05-2025
A25OB0100002	PFOS	0.008	µg/L	< 0.001	N35	Oberon treatment plant outlet	Enviro lab	12-05-2025	13-05-2025	16-05-2025