

NSW Drinking Water Database

Fluoride Compliance Detailed Report

Barcode	Characteristic	Guideline Value	Units	Value	Water Utility	Supply System	Sample Site Code	Lab Name	Date Collected	Date Received	Date Entered
325OB0100002	Fluoride	1.5	mg/L	1.01	Oberon Council	Oberon OB01	997	ICPMR-DAL Laboratory	03-02-2025	04-02-2025	06-02-2025
325OB0100002	Fluoride (WU result)	1.5	mg/L	1.07	Oberon Council	Oberon OB01	997	ICPMR-DAL Laboratory	03-02-2025	04-02-2025	06-02-2025
325OB0100002	Fluoride Ratio	0.8 - 1.2		1.0594059406	Oberon Council	Oberon OB01	997	ICPMR-DAL Laboratory	03-02-2025	04-02-2025	06-02-2025
325OB0100003	Fluoride	1.5	mg/L	1.	Oberon Council	Oberon OB01	5	ICPMR-DAL Laboratory	03-03-2025	04-03-2025	11-03-2025
325OB0100003	Fluoride (WU result)	1.5	mg/L	1.	Oberon Council	Oberon OB01	5	ICPMR-DAL Laboratory	03-03-2025	04-03-2025	11-03-2025
325OB0100003	Fluoride Ratio	0.8 - 1.2		1.	Oberon Council	Oberon OB01	5	ICPMR-DAL Laboratory	03-03-2025	04-03-2025	11-03-2025
325OB0100012	Fluoride	1.5	mg/L	0.96	Oberon Council	Oberon OB01	4	ICPMR-DAL Laboratory	31-03-2025	01-04-2025	04-04-2025
325OB0100012	Fluoride (WU result)	1.5	mg/L	1.	Oberon Council	Oberon OB01	4	ICPMR-DAL Laboratory	31-03-2025	01-04-2025	04-04-2025
325OB0100012	Fluoride Ratio	0.8 - 1.2		1.0416666666	Oberon Council	Oberon OB01	4	ICPMR-DAL Laboratory	31-03-2025	01-04-2025	04-04-2025
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.25	Oberon Council	Oberon OB01	F01		01-02-2025	N/A	N/A
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.25	Oberon Council	Oberon OB01	F01		02-02-2025	N/A	N/A
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.13	Oberon Council	Oberon OB01	F01		03-02-2025	N/A	N/A
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.05	Oberon Council	Oberon OB01	F01		04-02-2025	N/A	N/A
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.01	Oberon Council	Oberon OB01	F01		05-02-2025	N/A	N/A
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.06	Oberon Council	Oberon OB01	F01		06-02-2025	N/A	N/A
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	0.96	Oberon Council	Oberon OB01	F01		07-02-2025	N/A	N/A
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.03	Oberon Council	Oberon OB01	F01		08-02-2025	N/A	N/A
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	0.97	Oberon Council	Oberon OB01	F01		09-02-2025	N/A	N/A
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	0.94	Oberon Council	Oberon OB01	F01		10-02-2025	N/A	N/A
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.13	Oberon Council	Oberon OB01	F01		11-02-2025	N/A	N/A
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.18	Oberon Council	Oberon OB01	F01		12-02-2025	N/A	N/A
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.	Oberon Council	Oberon OB01	F01		13-02-2025	N/A	N/A
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.03	Oberon Council	Oberon OB01	F01		14-02-2025	N/A	N/A
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.05	Oberon Council	Oberon OB01	F01		15-02-2025	N/A	N/A
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.06	Oberon Council	Oberon OB01	F01		16-02-2025	N/A	N/A
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.07	Oberon Council	Oberon OB01	F01		17-02-2025	N/A	N/A
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.04	Oberon Council	Oberon OB01	F01		18-02-2025	N/A	N/A
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.01	Oberon Council	Oberon OB01	F01		19-02-2025	N/A	N/A
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	0.98	Oberon Council	Oberon OB01	F01		20-02-2025	N/A	N/A
Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	0.99	Oberon Council	Oberon OB01	F01		21-02-2025	N/A	N/A

[illegible]

Operational	Fluoride (daily WU)	0.9 - 1.5	mg/L	1.02	Oberon Council	Oberon OB01	F01		31-03-2025	N/A	N/A
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.92	Oberon Council	Oberon OB01	2		01-02-2025	N/A	N/A
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.93	Oberon Council	Oberon OB01	997		01-02-2025	N/A	N/A
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.05	Oberon Council	Oberon OB01	2		06-02-2025	N/A	N/A
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.05	Oberon Council	Oberon OB01	997		06-02-2025	N/A	N/A
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.05	Oberon Council	Oberon OB01	2		12-02-2025	N/A	N/A
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.05	Oberon Council	Oberon OB01	997		12-02-2025	N/A	N/A
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.06	Oberon Council	Oberon OB01	2		17-02-2025	N/A	N/A
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.06	Oberon Council	Oberon OB01	997		17-02-2025	N/A	N/A
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.99	Oberon Council	Oberon OB01	2		26-02-2025	N/A	N/A
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.99	Oberon Council	Oberon OB01	997		26-02-2025	N/A	N/A
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.01	Oberon Council	Oberon OB01	2		01-03-2025	N/A	N/A
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.01	Oberon Council	Oberon OB01	997		01-03-2025	N/A	N/A
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.03	Oberon Council	Oberon OB01	997		06-03-2025	N/A	N/A
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.05	Oberon Council	Oberon OB01	2		06-03-2025	N/A	N/A
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.05	Oberon Council	Oberon OB01	997		14-03-2025	N/A	N/A
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.06	Oberon Council	Oberon OB01	2		14-03-2025	N/A	N/A
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.99	Oberon Council	Oberon OB01	2		24-03-2025	N/A	N/A
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.	Oberon Council	Oberon OB01	997		24-03-2025	N/A	N/A
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.02	Oberon Council	Oberon OB01	2		31-03-2025	N/A	N/A
Operational	Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.02	Oberon Council	Oberon OB01	997		31-03-2025	N/A	N/A