

NSW Drinking Water Database
Fluoride Results August 2025 - March 2026

Characteristic	Guideline Value	Units	Value	Sample Site Code	Sample Site Location	Date Collected	Sample Comments
Fluoride	1.5	mg/L	1.03	2	Albion Street Oberon	04-08-2025	
Fluoride (WU result)	1.5	mg/L	1.1	2	Albion Street Oberon	04-08-2025	
Fluoride Ratio	0.8 - 1.2		1.07	2	Albion Street Oberon	04-08-2025	
Fluoride	1.5	mg/L	1.05	1	137 Oberon Street Oberon	01-09-2025	
Fluoride (WU result)	1.5	mg/L	1.01	1	137 Oberon Street Oberon	01-09-2025	
Fluoride Ratio	0.8 - 1.2		0.96	1	137 Oberon Street Oberon	01-09-2025	
Fluoride	1.5	mg/L	1.06	5	Tarana Road Oberon	29-09-2025	
Fluoride (WU result)	1.5	mg/L	1.03	5	Tarana Road Oberon	29-09-2025	
Fluoride Ratio	0.8 - 1.2		0.97	5	Tarana Road Oberon	29-09-2025	
Fluoride	1.5	mg/L	0.98	4	Carrington Avenue Oberon	01-12-2025	
Fluoride (WU result)	1.5	mg/L	1.02	4	Carrington Avenue Oberon	01-12-2025	
Fluoride Ratio	0.8 - 1.2		1.04	4	Carrington Avenue Oberon	01-12-2025	
Fluoride	1.5	mg/L	0.89	5	Tarana Road Oberon	03-11-2025	
Fluoride (WU result)	1.5	mg/L	0.99	5	Tarana Road Oberon	03-11-2025	
Fluoride Ratio	0.8 - 1.2		1.11	5	Tarana Road Oberon	03-11-2025	
Fluoride	1.5	mg/L	0.98	2	Albion Street Oberon	05-01-2026	
Fluoride (WU result)	1.5	mg/L	0.99	2	Albion Street Oberon	05-01-2026	
Fluoride Ratio	0.8 - 1.2		1.01	2	Albion Street Oberon	05-01-2026	
Fluoride	1.5	mg/L	0.93	2	Albion Street Oberon	02-03-2026	
Fluoride (WU result)	1.5	mg/L	1.05	2	Albion Street Oberon	02-03-2026	
Fluoride Ratio	0.8 - 1.2		1.13	2	Albion Street Oberon	02-03-2026	
Fluoride	1.5	mg/L	0.88	3	Fairfax Street Oberon	02-02-2026	
Fluoride (WU result)	1.5	mg/L	0.98	3	Fairfax Street Oberon	02-02-2026	
Fluoride Ratio	0.8 - 1.2		1.11	3	Fairfax Street Oberon	02-02-2026	
Fluoride (daily WU)	0.9 - 1.5	mg/L	0.06	F01	Oberon Water Treatment Plant Fluoride Monitoring Site	12-12-2025	,operator error. left supply tap off after performing drop test. reservoir F levels 0.71, 0.82, and 0.94 over the next 3 days
Fluoride (daily WU)	0.9 - 1.5	mg/L	0.7	F01	Oberon Water Treatment Plant Fluoride Monitoring Site	15-02-2026	,As per above.
Fluoride (daily WU)	0.9 - 1.5	mg/L	0.74	F01	Oberon Water Treatment Plant Fluoride Monitoring Site	03-02-2026	,Operator error, supply tap left off, reticulation town value 0.94
Fluoride (daily WU)	0.9 - 1.5	mg/L	0.816	F01	Oberon Water Treatment Plant Fluoride Monitoring Site	14-02-2026	System returned to normal ,As per above.
Fluoride (daily WU)	0.9 - 1.5	mg/L	0.854	F01	Oberon Water Treatment Plant Fluoride Monitoring Site	24-09-2025	,needed to load 2 bags of Na fluoride into the system. next day the fluoride level was normal
Fluoride (daily WU)	0.9 - 1.5	mg/L	0.86	F01	Oberon Water Treatment Plant Fluoride Monitoring Site	09-01-2026	
Fluoride (daily WU)	0.9 - 1.5	mg/L	0.866	F01	Oberon Water Treatment Plant Fluoride Monitoring Site	13-02-2026	,Form 5 submitted, concerned that a flow meter paddle may have been broken. Upon investigation all good. System needed two bags of fluoride loaded. System returned to normal after 3 days
Fluoride (daily WU)	0.9 - 1.5	mg/L	0.89	F01	Oberon Water Treatment Plant Fluoride Monitoring Site	07-10-2025	,Short term dose failure, problem was rectified.
Fluoride (daily WU)	0.9 - 1.5	mg/L	0.89	F01	Oberon Water Treatment Plant Fluoride Monitoring Site	03-11-2025	,dosing system needed loading with Na Fluoride. Reticulation Fluoride levels unaffected
Fluoride (daily WU)	0.9 - 1.5	mg/L	0.905	F01	Oberon Water Treatment Plant Fluoride Monitoring Site	25-02-2026	
Fluoride (daily WU)	0.9 - 1.5	mg/L	0.91	F01	Oberon Water Treatment Plant Fluoride Monitoring Site	30-10-2025	
Fluoride (daily WU)	0.9 - 1.5	mg/L	0.91	F01	Oberon Water Treatment Plant Fluoride Monitoring Site	02-02-2026	
Fluoride (daily WU)	0.9 - 1.5	mg/L	0.928	F01	Oberon Water Treatment Plant Fluoride Monitoring Site	23-09-2025	
Fluoride (daily WU)	0.9 - 1.5	mg/L	0.93	F01	Oberon Water Treatment Plant Fluoride Monitoring Site	05-10-2025	
Fluoride (daily WU)	0.9 - 1.5	mg/L	0.947	F01	Oberon Water Treatment Plant Fluoride Monitoring Site	11-02-2026	

Fluoride (daily WU)	0.9 - 1.5	mg/L	1.26	F01	Oberon Water Treatment Plant Fluoride Monitoring Site	18-02-2026	
Fluoride (daily WU)	0.9 - 1.5	mg/L	1.28	F01	Oberon Water Treatment Plant Fluoride Monitoring Site	13-12-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.92	2	Albion Street Oberon	23-10-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.954	2	Albion Street Oberon	17-02-2026	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.965	1	137 Oberon Street Oberon	17-02-2026	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.97	2	Albion Street Oberon	08-10-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.98	1	137 Oberon Street Oberon	08-10-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.98	1	137 Oberon Street Oberon	23-10-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.98	1	137 Oberon Street Oberon	15-12-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.99	1	137 Oberon Street Oberon	14-08-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.99	2	Albion Street Oberon	01-09-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.99	1	137 Oberon Street Oberon	01-09-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.99	1	137 Oberon Street Oberon	22-09-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.99	2	Albion Street Oberon	15-12-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	0.996	2	Albion Street Oberon	02-10-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.	2	Albion Street Oberon	14-08-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.	1	137 Oberon Street Oberon	02-10-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.	2	Albion Street Oberon	13-11-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.	1	137 Oberon Street Oberon	13-11-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.	1	137 Oberon Street Oberon	29-12-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.01	2	Albion Street Oberon	15-09-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.01	1	137 Oberon Street Oberon	15-09-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.01	1	137 Oberon Street Oberon	30-09-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.01	2	Albion Street Oberon	03-11-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.01	1	137 Oberon Street Oberon	03-11-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.01	2	Albion Street Oberon	08-01-2026	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.01	1	137 Oberon Street Oberon	08-01-2026	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.01	2	Albion Street Oberon	02-02-2026	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.02	2	Albion Street Oberon	01-08-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.02	1	137 Oberon Street Oberon	01-08-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.02	2	Albion Street Oberon	22-09-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.02	2	Albion Street Oberon	30-09-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.02	1	137 Oberon Street Oberon	08-12-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.02	2	Albion Street Oberon	29-12-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.02	2	Albion Street Oberon	01-01-2026	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.02	1	137 Oberon Street Oberon	01-01-2026	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.02	1	137 Oberon Street Oberon	02-02-2026	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.02	2	Albion Street Oberon	23-02-2026	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.02	1	137 Oberon Street Oberon	23-02-2026	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.03	2	Albion Street Oberon	07-08-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.03	1	137 Oberon Street Oberon	07-08-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.03	1	137 Oberon Street Oberon	29-08-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.03	2	Albion Street Oberon	08-09-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.03	2	Albion Street Oberon	01-12-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.03	1	137 Oberon Street Oberon	01-12-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.03	2	Albion Street Oberon	22-12-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.03	1	137 Oberon Street Oberon	22-12-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.03	2	Albion Street Oberon	15-01-2026	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.03	1	137 Oberon Street Oberon	15-01-2026	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.03	1	137 Oberon Street Oberon	22-01-2026	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.03	2	Albion Street Oberon	30-01-2026	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.03	1	137 Oberon Street Oberon	30-01-2026	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.03	2	Albion Street Oberon	09-02-2026	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.03	1	137 Oberon Street Oberon	09-02-2026	

Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.04	2	Albion Street Oberon	29-08-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.04	1	137 Oberon Street Oberon	30-10-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.04	1	137 Oberon Street Oberon	20-11-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.04	2	Albion Street Oberon	22-01-2026	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.05	1	137 Oberon Street Oberon	21-08-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.05	2	Albion Street Oberon	15-10-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.05	2	Albion Street Oberon	30-10-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.05	2	Albion Street Oberon	20-11-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.05	2	Albion Street Oberon	08-12-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.05	2	Albion Street Oberon	27-02-2026	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.05	1	137 Oberon Street Oberon	27-02-2026	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.06	2	Albion Street Oberon	21-08-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.06	1	137 Oberon Street Oberon	08-09-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.06	1	137 Oberon Street Oberon	15-10-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.06	2	Albion Street Oberon	07-11-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.06	1	137 Oberon Street Oberon	07-11-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.06	1	137 Oberon Street Oberon	27-11-2025	
Fluoride (weekly WU)	0.9 - 1.5	mg/L	1.07	2	Albion Street Oberon	27-11-2025	